

Team:	Unison, J. F. Ahern, Strand Associates, City of Fond du Lac, Biorem
Application:	Municipal AD
Gas Type:	Biogas
Air Flow Rate:	150 SCFM (240 Nm ³ /h)
Media:	Biopack
System Details:	10' diameter x 25' tall, insulated, FRP tank
H ₂ S Inlet:	5,000 ppm
H ₂ S Outlet:	<250 ppmv
Gas End Use:	450 kW Engine
Commissioned:	September 2012

